




Product Service

CERTIFICATE

No. Z2 118771 0033 Rev. 00

Holder of Certificate: **Zhejiang Sunpro Power
Technology co., Ltd**
Qinggang Technological Ind.Zone
317606 Yuhuan, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262525103-00

Valid until: 2029-07-10

Date, 2025-12-15

(Zhulin Zhang)



CERTIFICATE

No. Z2 118771 0033 Rev. 00

Model(s): SPDGxxx-BC108RL10 (xxx=460 to 495, in step of 5)
 SPDGxxx-BC120RL10 (xxx=520 to 550, in step of 5)
 SPDGxxx-HIBC108RL10 (xxx=485 to 515, in step of 5)
 SPDGxxx-BC132R12 (xxx=625 to 670, in step of 5)
 xxx stands for rated output power at STC.

Parameters:

Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire safety Class:	Class C according to UL790
Construction:	Framed or framless, with Junction box, Cable and Connectors.

Tested according to:

- IEC 61215-1:2021
- IEC 61215-1-1:2021
- IEC 61215-2:2021
- IEC 61730-1:2023
- IEC 61730-2:2023
- IEC 62716:2013